

The meter compartment of the meter base must be at least 11 inches wide

Center of Base
42 Inches Above Ground

Ring-type meter bases will not be accepted

2" Rigid Metal or Sch 80 U.L.
Approved PVC Conduit

#4 Copper Ground Wire

5/8" X 8' Ground Rod
Driven Flush with or
Below Ground Level

MAIN DISCONNECT SWITCH

Conduit Straps 2' Apart

6" X 6" Treated Post

2 Foot Deep Trench

4-Wires to
Mobile Home

Source

Pole Depth Approx. 3 Feet

Please contact North Arkansas Electric Cooperative's engineering department at 870-895-6213 before beginning work.

Revisions		North Arkansas Electric Cooperative, Inc.				
		Salem, Arkansas		Arkansas-26-Fulton		
200 Amp Service PEDESTAL - METER BASE DISCONNECT COMBINED						
		Date	Chk'd By	Drawn By	Scale	Dwg. No.
#	Description	Date		RE		MPED2