

The meter compartment of the meter base must be at least 11 inches wide  
Center of Base  
42 Inches Above Ground

Ring-type meter bases will not be accepted

MAIN DISCONNECT SWITCH

3" Rigid Metal or Sch 80 U.L. Approved PVC Conduit

#2 Copper Ground Wire

5/8" X 8' Ground Rod Driven Flush with or Below Ground Level

Conduit Straps 2' Apart

6" X 6" Treated Post

2 Foot Deep Trench

4-Wires to Mobile Home

Pole Depth Approx. 3 Feet

Source

Please contact North Arkansas Electric Cooperative's engineering department at 870-895-6213 before beginning work.

Revisions			North Arkansas Electric Cooperative, Inc.			
			Salem, Arkansas		Arkansas-26-Fulton	
320 Amp Service PEDESTAL - METER BASE DISCONNECT COMBINED						
	Date	Chkd By	Drawn By	Scale	Dwg. No.	
#	Description	Date	053100	RE		MPED2